



Certificate No.
T - 2661

TEST REPORT

Name of Organization : M/s. Mumbai Education Trust (MET)			
Address : Bhujbal Knowledge City, Nashik			
Customers Reference : ---			
Sample Code : NIL/W/02/17/002	Sample Source : STP Outlet		
Sampling Location : STP Outlet	Sample Qty.& Packing : Plastic Can (2 lit)		
Sampling Procedure : APHA1060 B&C	Sample Appearance : Clear Liquid		
Sample Type : Waste water	Sample Not Drawn By : Netel (India) Limited.		
Sampling Date	Sample Received Date	Date of Analysis	Report Date
02.02.2017	02.02.2017	03.02.2017- 07.02.2017	08.02.2017

Sr. No.	Test Parameter	Method	Unit	Result	MPCB Limit
1	pH Value	APHA 4500-H ⁺ -B 22 nd Edition 2012	--	7.93	6.5 - 8.5
2	Total Suspended Solids (TSS)	APHA 2350-D 22 nd Edition 2012	mg/l	9	10
3	Chemical Oxygen Demand (COD)	APHA 5220-B 22 nd Edition 2012	mg/l	27.4	30
4	Biochemical Oxygen Demand (BOD) 3day 27°C	IS 3025(Part 44):1993 R2009	mg/l	8.7	10
5	Oil & grease*	APHA 5520-B 22 nd Edition 2012	mg/l	<0.2	5.0

BDL-Below Detection Limit


Remark: All parameters are within limit.

- Note: -
1. This Test Report shall not be reproduced except in full, without written approval of the Laboratory.
 2. This Test Report refers only to the sample tested.
 3. The Test Parameters marked with an * are not accredited by NABL.

Verified by:


Chetan Kadam
Dy. Technical Manager



Issued by:

Shraddha Kere
Technical Manager